

BUILDING DIGEST

CENTRAL BUILDING RESEARCH INSTITUTE, INDIA



COOLING LOAD AND INDOOR AIR TEMPERATURE OF OFFICE BUILDINGS UNDER TROPICAL CLIMATE

The indoor thermal conditions depend on many factors such as climatic condition, thermal characteristics of materials used in the structure and utility. Methods are available to precisely include all these factors in the computation of cooling loads and indoor air temperatures. To account for all these factors, about 30 cases were studied. A double-storey building having number of rooms in a row was considered for the purpose. The envisaged plan of the building is shown in Fig. 1. General

features of the building considered are given below :

Walls : 23 cm brick with plaster on both sides.

Roof : 9 cm lime concrete over 10 cm R.C.C. slab.

Intermediate floor : 15 cm R.C.C. slab.

Floor : 2.5 cm cement concrete + 7.5 cm brick blast + 20 cm soil.

Window : all on longer wall, 3 mm glass, $12\frac{1}{2}\%$ of floor area or 25% of wall area.

Door : 2.5 cm teak wood.




Fig. 1. Plan of the building studied.

People : 40
Furniture : 40 tables and chairs
Ventilation : 4 air changes/hour

Venetian blinds were considered whenever the glass area was fully sunlit.

Rating Criterion

For conditioned buildings, the volume of air cooled to 25°C by a one-ton refrigeration unit has been taken as the basis. Peak degree hours above a base temperature of 30°C forms the basis of rating unconditioned building. However, in case of unconditioned buildings, 6°C of peak degree hours has been taken as equivalent to 100 in T.P.I. A.T.P.I. value of 50 or less should provide comfortable indoor conditions. Furthermore, the more the volume of air cooled by one ton of refrigeration the better is the enclosure. Based on these criteria, the data for all the 30 cases has been

computed and given in table 1.

From the data presented in table 1, computation of cooling load for a particular enclosure is simple. An illustrative example for the computation of peak indoor air temperature from the T.P.I. values is as follows :

Example

A south oriented building has an inner room on bottom floor. The glass area is 25% of the wall area and is shaded. The number of air changes are 4 per hour. Calculate the peak indoor air temperature.

From table 1 the T.P.I. value (ref A)=122
Therefore

$$\begin{aligned} \text{Peak indoor air temperature} &= \frac{122 \times 6}{100} + 30 \\ &= 7.2 + 30 \\ &= 37.2 \text{ }^\circ\text{C.} \end{aligned}$$

There is a demand for short notes summarising available information on selected building topics for the use of Engineers and Architects in India. To meet the need this Institute is bringing out a series of Building Digests from time to time and the present one is the 104th in the series. Readers are requested to send to the Institute their experience of adopting the suggestions given in this Digest.

Prepared by Prakash Chandra
Published by S. Srinivasan
Central Building Research Institute
Roorkee, India.

July 1973.

SfB	Ab 8
U.D.C. 697.97	

Lakshmi Printers, Saharanpur (India)


TABLE I
Thermal Performance values of Office Buildings for Various
Combinations of Thermal Factors

DESIGNATION	C A S E	Orientation	Glass area. Shaded or Glazed	Location	Remarks	* Volume m ³ /ton	† T.P.I. Value
A		South	25%, Shaded	Inner room, bottom floor		54.5	122
B		„	25% Shaded	End room, bottom floor		51.0	125
C		„	25% Shaded	End room, bottom floor		52.8	117
D		East	25% Glazed inside venetian blind are used	Inner room, top floor	Roof exposed	48.2	177

* Conditioned

† Unconditioned

P L A N



DESIGNATION	Orientation	Glass area Shaded or Glazed	Location	Remarks	Volume * m ³ /ton	T.P.I. † value
F3	East	25% Glazed, inside venetian blinds	End room, top floor	Roof exposed	47.4	170
F4	"	25% Glazed, inside venetian blinds	End room, top floor	Roof exposed	47.5	170
O1	"	25% Shaded	End room, bottom floor		51.8	122
O5	"	25% Glazed	End room, bottom floor		53.4	133

* Conditioned
 † Unconditioned

DESIGNATION	PLAN	Orientation	Glass area Shaded or Glazed	Location	Remarks	Volume * -m ³ /ton	T.P.I. value †
02		South	25% Shaded	End room, bottom floor		52.8	117
06		"	25% Glazed	End room, bottom floor		49.8	127
03		West	25% Shaded	End room, bottom floor		53.1	118
07		"	25% Glazed	End room, bottom floor		52.0	133
04		North	25% Shaded	End room, bottom floor		53.4	113
08		"	25% Glazed	End room, bottom floor		55.5	108
R1		South	25% Shaded	Inner room, bottom floor		54.5	122
R2		"	25% Shaded	Top floor $\alpha=0.7$		47.7	167
R3		"	25% Shaded	Top floor $\alpha=0.3$		53.7	125
R4		"	25% Shaded	Top** floor $\alpha=0.7$		52.8	165

** Roof, 2.5 cm Thermocole above 10 cm R.C.C.+1.5 cm plaster.

* Conditioned

† Unconditioned

DESIGNATION	PLAN		Orientation	Glass area Shaded Glazed	Location	Remarks	* Volume m ³ /ton.
			East	12½% Glazed	Inner room, bottom floor	—	57.5
G1			"	25% Glazed	"	—	54.3
G2			"	50% Glazed	"	—	43.2
G3			"	75% Glazed	"	—	35.4
G4			"	12½% Shaded	"	—	56.4
G5			"	25% Shaded	"	—	52.7
G6			"	50% Shaded	"	—	46.7
G7			"	75% Shaded	"	—	41.9
G8			South	25% Shaded	Inner room, bottom floor	2 †	71.3
V1	"	"	"	3 †	59.3		
V2	"	"	"	4 †	54.5		
V3	"	"	"	5 †	48.8		
V4							

*Condition
†Unconditioned
‡No. of air changes per hr.